

LANEY COLLEGE BEGINNER'S INN EXHAUST SYSTEM MODIFICATIONS

DOCUMENT 00 9113

ADDENDA

BID NO. 17-18/29

Peralta Community College District

Laney College Beginner's Inn Exhaust System Modifications

900 Fallon Street Oakland, CA 94607

March 21, 2018

ADDENDA No. 1

This addendum supersedes items of the original contract documents wherein it is inconsistent with it. All other conditions remain unchanged. The following changes, modifications, corrections, additions or clarifications shall apply to the contract documents and shall be made a part of and subject to all of the requirements thereof as if originally specified or shown. It is the responsibility of the bidder to review the list of attachments to ensure that the addendum is full and complete. This Addendum modifies the original Bid Documents for the above Bid. **Acknowledge receipt of this addendum in the space provided on the BID FORM. Failure to do so may subject Bidder to disqualification.**

Revisions\Additions

1. The Substantial Completion date has been changed from 30 days to **60 days.**
2. The electrical conduit routing from existing electrical panels to the new Exhaust Fans will be over a 100 feet away and is not shown on the drawings. Please clarify where and how we should be performing these routes.

Answer: The location of the existing electrical panels and the equipment are all identified in the plans. Route conduits with minimum bends in the shortest practical distance Final conduit routing to conform with field existing conditions.

3. Who is the existing campus Energy Management System?

Answer: Delta Controls

END OF DOCUMENT