

**DISTRICT –WIDE EMERGENCY BLUE PHONES**

**DOCUMENT 00 9113**

**ADDENDA**

**BID NO. 16-17/13**

**Peralta Community College District**

District –Wide Emergency Blue Phones  
333 East 8th Street, Oakland, CA 94606

February 22, 2017

**ADDENDUM No. 2**

This addendum supersedes items of the original contract documents wherein it is inconsistent with it. All other conditions remain unchanged. The following changes, modifications, corrections, additions or clarifications shall apply to the contract documents and shall be made a part of and subject to all of the requirements thereof as if originally specified or shown. It is the responsibility of the proposer to review the list of attachments to ensure that the addendum is full and complete. This Addendum modifies the original RFP Documents for the above RFP. **Acknowledge receipt of this addendum in the space provided on the Proposal Form. Failure to do so may subject Proposer to disqualification.**

**Responses to Request for Information:**

Attached are two pages of responses to questions by Security By Design.

Also part of Addendum Two is the re-issuance of all thirty-five project drawings, which can be found at the District website.

**END OF DOCUMENT**

## RFI Response

Security By Design  
5528 Pacheco Blvd, Suite B-100  
Pacheco, CA 94553  
Phone: 925-609-1000 Fax: 925-609-1001



# RFI-1 Response

**Project Name:** Peralta Community College District  
**Project Location:** Oakland, Ca  
**Subject:** District-Wide Emergency Blue Phone, Re-Bid RFIs  
**Response:** February 16, 2017  
**Attention:** Osafran Okundaye, John      **From:** Eric Reither, Sr Consultant  
Hiebert  
**CC:** Chris Walters, Consultant

Item#	Response
20170216-01	<p><b>Question</b> – On sheet SE1.L.01a, Sheet Note 5 indicates a new speaker horn to be installed on the Admin Tower. This device does not appear on the Security Point Schedule. Please specify if this speaker should be part of the base bid or the add alternate bid.</p> <p><b>Answer</b> – Sheet Note 5 will be deleted from Plan SE1.L.01a and updated as part of Addendum-2 that is expected to be issued on 2/22/17.</p>
20170216-02	<p><b>Question</b> – On sheet SE1.L.01d, please confirm that the new intercom stations located in the District Office Headquarters and Department of General Services Processing Center are not to be connected to the Laney College battery backup plant located in the Admin Tower.</p> <p><b>Answer</b> – Confirmed. (Also refer to Response #20170216-03) Sheet Notes 12 applies to all intercoms in the District Office building and will be updated as part of Addendum-2.</p>
20170216-03	<p><b>Question</b> – On sheet SE1.L.01d, Sheet Note 11 does not appear to be referenced on the site plan. Please confirm Sheet Note 11 applies to the General Services / Data Processing Center intercoms.</p> <p><b>Answer</b> – Sheet Note 11 applies to all intercoms in the General Services/Data Processing Center building and will be updated as part of Addendum-2.</p>
20170216-04	<p><b>Question</b> – On sheet SE0.03, the Bid Form indicates a lump sum total for the entire project. Drawing SE0.03 labels some of the devices as Base Scope and some as Add Scope. Please clarify if the items labeled as Add Scope should be included in the Bid Form's lump sum total</p> <p><b>Answer</b> – No, the Add Alternate stations are to be broken out separately. Refer to Specification 280001 1.01.A &amp; 1.07.A.3, sheet SE0.03 Point Schedule under the SCOPE column, and Sheet Notes on each plan.</p> <p>The intent is for the bidders to provide a total installed price for all Base Bid devices and headend equipment that supports up to 138 stations. Each Add Alternate station should be broken out as a standalone installed price. An added price to</p>

## RFI Response

Security By Design  
5528 Pacheco Blvd, Suite B-100  
Pacheco, CA 94553  
Phone: 925-609-1000 Fax: 925-609-1001



	<p>upgrade the Stentofon license to 276 (part no. 1009647803) should be included in case the final station count exceeds 138 stations.</p>
20170216-05	<p><b>Question</b> – Verify the part number on Line Item #2 for Detail SG.</p> <p><b>Answer</b> – Detail SG will be updated to change the Turbine IP Relay Board to part number 1000140224 as part of Addendum-2.</p>
20170216-06	<p><b>Question</b> – Verify the part number on Line Items #1, 2, &amp; 3 for Detail SF.</p> <p><b>Answer</b> – Detail SF will be updated to change the Turbine Video Intercom to part number 1008115020, the IP Relay Board to part number 1000140224, and Adapter Plate to part number 1072160000 as part of Addendum-2.</p>
20170216-07	<p><b>Question</b> – Verify the part number on Line Item #3 for Detail SE. Verify function of two buttons.</p> <p><b>Answer</b> – Detail SE will be updated to change the Emergency Wall Unit to part number 2809016029 as part of Addendum-2.</p> <p>Only Berkeley Campus has two button stations. One calls the on-site guard master station and one calls the 911 dispatch at Berkeley PD. Refer to Specification Section 280001, 1.01.C and 285031, 1.01.A.1 for additional operational description.</p>
20170216-08	<p><b>Question</b> – Sheet SE6.01 shows SNOM phones but does not have included in the Equipment List. Please provide part numbers.</p> <p><b>Answer</b> – Detail SA includes the SNOM phone (part number 1000141219) and the associated license (part number 1009643001).</p>