

ADDENDA

RFP NO. 17-18/09

Peralta Community College District

November 16, 2017

RFP 17-18/09 HVAC Design Build Services, 860 Atlantic Avenue

ADDENDUM No. 2

This addendum supersedes items of the original contract documents wherein it is inconsistent with it. All other conditions remain unchanged. The following changes, modifications, corrections, additions or clarifications shall apply to the contract documents and shall be made a part of and subject to all of the requirements thereof as if originally specified or shown. It is the responsibility of the bidder to review the list of attachments to ensure that the addendum is full and complete. This Addendum modifies the original RFP Documents for the above Proposal. **Acknowledge receipt of this addendum in the space provided on the Proposal. Failure to do so may subject Proposer to disqualification.**

Revisions:

Below, is a description of the 860 Atlantic request to upgrade the electrical distribution for the Cadaver Room.

- A. Air Conditioner (AC-1) and Exhaust Fan (EF-8, general room exhaust) serving Cadaver Room 131

- 1. Provide AC-1 and EF-8 power from emergency power panel.

Note EF-14 (Cadaver dedicated ducted exhaust) is already fed from emergency power panel EL-

- 2. Room thermostat doesn't allow adjustments ("locked out").

Provide AC-1 unit operating status feedback to the Delta controls enabling an alarm if fails, current points shown below and only enables the unit.

860 Atlantic: AC Units							
AC	Zone Description	Enable	Status	Zone Temp	Supply Temp	High Temp. Alarm	Condensate Alarm
1	*****	On					
2	*****	On	On	73.0 °F	76.6 °F	Off	Off
3	*****	On	On	-58.0 °F	73.1 °F	Off	Off
4	*****	On	On	69.6 °F	72.7 °F	Off	Off
5	*****	On	On	69.6 °F	73.1 °F	Off	Off



OAT 63.4 °F

End of Addendum Two